

### Intermediate winter 2012-2013 review

Wim Michiels





### Introduction

Since summer 2012 until at least end of March 2013: Forced Outage of NPP Doel 3 and Tihange 2 (~2000 MW)

- → Asssessment of impact before winter
- $\rightarrow$  Mitigating actions in order to control the risks
- → Review of winter period and impact on Security of Supply

# Actions undertaken by Elia to mitigate the risks



- Information & communication to market parties and policy makers → risk awareness;
- Fine tune procedures & processes in case of energy shortage with authorities and DSO's;
- Maximize 380 & 220 kV grid availability and generation during the winter period
- Increase the volume of contracted **interruptible (industrial)** load during this winter period;
- Agreements with TenneT (Dutch TSO):
  - increase commercial capacity (day ahead and intra-day) on the Belgian-Dutch border with a maximum of (non-guaranteed after positive security assessment) 300 MW;
  - contract for R3 pooling and emergency exchange of 300 MW;
- Operational risk indicators (see next slide)
- "warning light" indicator on **Elia website** (see next slide)
- Coordination with CWE TSO's & Coreso to assess risks and possible remedial actions

# Monitoring of the risk example

## **D0 D-7 dashboard**

elia	1050 D	₩50 <b>D+1</b>	₩50 <b>D+2</b>	₩50 <b>D+3</b>	₩50 <b>D+4</b>	₩50 D+5	₩50 <b>D+6</b>	₩5/ D+7
Temperature	10/12/2012	11/12/2012	12/12/2012	13/12/2012	14/12/2012	15/12/2012	16/12/2012	17/12/2012
Remaining margin current imports	with							
Remaining margin ( max imports	with							
Remaining margin no imports	with							
Eq. Temperatur Peak load (MW Import @ Peak lo	e 3.08 ) 12412 ad -1740	0.64 12865 -1740	-0.93 12955 -1740	-1.47 12472 -1740	2.14 12150 -1740	4.96 10691 -1740	6.39 10090 -1740	6.41 11612 -1740
SCARCITY INDICATOR	Level 1	Level 1	Level 1	Level 1	Level 0	Level 0	Level 0	Level 0





## Communication Elia web site



#### BALANCE BETWEEN ELECTRICITY OFFER AND DEMAND IN BELGIUM





### **Conclusions on risks before start of winter**

- Belgium will be structural **dependent upon import**, even in **normal** winter conditions
- In extreme winter conditions (e.g. cold spell in Europe in February 2012), risk on scarcity exist and could lead to demand limitation/ prohibition measures and in extreme situation to load shedding.
- 3500 MW import capacity available BUT Market players have to buy energy on (international) market

### ENTSO-E winter outlook 2012-2013 (November 30<sup>th</sup> 2012)

- confirmed the import dependency of Belgium and
- concluded that, in case of low temperatures in Europe especially in France, this could lead to non-manageable flows on Elia grid or risks of scarcity.



# **Review of the winter and impact on SoS**

### **Belgian (physical) import:** November 1st – end of Jan (max. MW of the day)





- If > 3500 MW: accepted case by case, only after security check by experts.
- 29 days > 3000 MW import; partly for economic reasons (e.g. 19/11/2012 max. 3864 MW).

### End 2012, up to 15 January 2013



### Until end of 2012:

Mild winter; some problems of incompressibility (lack of flexibility) during the holiday period (Christmas - New Year). The control area was occasionally "too long".

Friday 11 January 2013 : A 24h forced outage of an another large NPP raised the total level of imports to 3788 MW (intraday).

**Security evaluation** in case of longer delay:

- France >  $0^{\circ}C \rightarrow$  exporting, so Belgium could import from N and S.
- French peak load ~90 GW compared to 102 GW during cold spell February 2012
- If all available Belgian units would have been used, this would lead to max. imports of 3600 MW (which was acceptable) but no more margins left in case of another FO.
- Close follow up of repair + ready for new analysis during weekend
- → manageable

## Cold spell 16-25 January In general



Day time temperatures

- < 0°C in Belgium</p>
- Cold in NL, B, D, but only half France

France (2300 MW/°C)

- Maximum load 92 GW compared to 102 GW record value Feb. 2012
- High generation availability
- Mostly exporting; only importing on 17 January

Belgium

- High generation availability (of course except D3 & T2)
- Possibility to import energy from both North and South → no specific problems or risks for SOS are encountered.
- Margins after a possible forced outage (N-1) are reduced to zero.
- Most critical day up till now was <u>January 17th</u> (next slide)

# Cold spell 16-25 January: focus on 17 January

Load Elia grid ~13.2 GW Import on January 15th: **3450 MW** 

### January 17th:

- Day-1 Belpex 180 EUR/MWh @ evening peak → start up of additional available conventional generation in B.
- France changed from export to import (2700 MW) at evening peak
- Unplanned outages (total ~1000 MW) before evening peak:
- $\rightarrow$  Elia activated all reserves:
  - Use of all free bids
  - Activation aggregator REstore
  - Contractual Industrial Interruptables, included additional "winter"
  - R3 reserve units started: 300 MW
- → During evening peak all margins were exhausted
- → Intraday trades allowed to free up again margins



### Cold wave 16-25 January: week 4

**Comparable** to previous week 3

- With lower freezing t° during day
- But higher generation availibility in Belgium

Max import level on 23 January was 3546 MW

Relatively low load France (86,3 HW) → import capacity available on both North and South border

## Conclusions Nov2012 - Jan2013



- Overall availability (except D3&T2) of the generation portfolio in Belgium was very high.
- Maximal availability of generation and grid in CWE region
- Such high availability not feasible every year due to limited delay for outages and inspection of units
- Belgium structurally dependent upon imports
  - we observed (due to economical reasons) import levels to 3500 MW.
  - 29 days above 3000 MW (25% of winter load)
- Energy was available in Europe thanks to limited winter load (t° South France 10° C => 10 000 MW less load F) and high availability of French generation
- Import- export situation of France (and hence load in France) is crucial.
  - When France exports, no issues to import 3500 MW in B.
  - When France imports (very cold in whole of France) → non-manageable flows or scarcity is possible.
- During cold spell (e.g. Jan 17<sup>th</sup>) → reduced margins; an additional big incident would have triggered the emergency plan.